



PUBLIC WORKS DEPARTMENT

AN ISO 9001-2008 CERTIFIED DIVISION

No: AEE/No.1 Bld Sub Dvn/V.V. Centre /2023-24/ 26

Dated: 08.04.2024

APPENDIX - XI


BUILDING SAFETY CERTIFICATE

Certified that the existing building "HOLY ANGLES HIGHER PRIMARY SCHOOL, St. Joseph Convent," at Frazer Town, Bengaluru - 560005. comprised of Block-1 Ground floor & 04 upper floors, Block-2 Ground floor and 03 upper floors owned/occupied by HOLY ANGLES HIGHER PRIMARY SCHOOL, have complied with the Building safety requirements in accordance with National Building code Rules. The trust has taken necessary tests of Safety Check report, Physical observation, Investigating studies, Rebound hammer test, Ultra Sonic test report, Ultra Sonic pulse velocity test - by M/s. Karnataka Test House Pvt. Ltd., No. 778/44, 8th Cross, Triveni Road, Gokul 1st Stage, 2nd Phase, Bangalore - 560054.

The building verified by the officers concerned of Public Works Department, No. 1 Buildings Sub-division, V.V. Centre, Bangalore on 22-06-2022, 02-03-2023 & 05-04-2024 in the presence of Sister Rashmie, Principal and that the building/premises is fit for occupancy for running school with effect from 06-04-2024 for a period of one year in accordance with rule and subject to compliance of the specific conditions as appended.

- 1) The school should take necessary certificates from Fire department and other competent authorities within the time.
- 2) Building should be maintained neatly using good materials and experts.
- 3) The school should follow necessary safety precautions of students & teachers.
- 4) In the time of any changes in the structure of school building the school should take permission from competent authority. Otherwise this certificate will get cancelled without any conditions.
- 5) The school should maintain neatly of drinking water facility, toilet neatness and other conditions from BBMP which are applied for schools and colleges.

Issued on : 06-04-2024


Assistant Executive Engineer
No. 1, Buildings Sub-Division
BANGALORE - 560 001